

ISSN 2249-3352 (P) 2278-0505 (E)

Cosmos Impact Factor-5.86

Design and Analysis of PV/Battery based UPQC with ANN controller to enhance Power Quality of Grid tied Microgrid

JARUPULA MYNA¹, V. SATYANARAYANA² 1, PG Scholar, Department of Electrical and Electronics Engineering 2, Associate Professor, Department of Electrical and Electronics Engineering Vaagdevi College of Engineering, Bolikunta, Warangal(Dt), TS, India. jarupulamyna810@gmail.com

Abstract: This research introduces a novel approach to managing power quality in PVBSS systems, significantly enhancing their reliability. It employs Fractional Order Control with Artificial Neural Networks (ANNs), eliminating the need for traditional transformations such as abc and dq0. The proposed system utilizes UPQCs and Levenberg-Marquardt-trained Fractional Order Control-based ANN Controllers (ANNCs) to directly provide reference signals to the shunt and series converters. Optimal power extraction under various conditions is achieved through an MPPT system based on High-Frequency Switching Modulation Control (HFSMC), aimed at maximizing the efficiency of photovoltaic (PV) solar energy harvesting devices.

The integration of a Battery Storage System (BSS) supports a stable DC link voltage, enabling a faster response to load and solar irradiation fluctuations. The proposed method seeks to mitigate grid voltage spikes and dips, improve power factor, and reduce current harmonics. Compared to conventional Proportional-Integral Controllers (PICs), this approach enhances power quality, reduces Total Harmonic Distortion (THD), and shortens the settling time of the DC link voltage. Future research will explore heuristic methods for fine-tuning system parameters to further optimize efficiency.

Key Words: Photovoltaic system, Battery energy storage system, UPQC, MPPT, FO-ANN and HFSMC.

I. Introduction

Currently, power quality (PQ) issues in distribution systems (DS) arise from the presence of harmonics generated by power electronic-based appliances, drives, and other nonlinear loads. In order to mitigate the effects of PQ-related problems, a solution was suggested: the use of an active power filter (APF). The UPQC was introduced to effectively address power quality (PQ) issues in distribution networks that are associated with voltage and current. This is achieved by integrating a shut active power filter (SHAPF) and a series active power filter (SAPF) through a shared DC link. Various control methods have been developed for unified power quality conditioners, such as PIC, artificial intelligence (AI) techniques like ANNs and fuzzy logic, park's and Clarke's transformations approaches, and others (Fujita and Akagii, 1998).

The PQ enhancement debates encompassed the design and research of unified PQ conditioners, which integrate both SHAPF and SAPF along with a dynamic voltage restorer (Kolhatkar, Errabelli, and Das 2005; Mosaad et al. 2022). In order to address the issue of Page | 303



ISSN 2249-3352 (P) 2278-0505 (E)

Cosmos Impact Factor-5.86

harmonics and grid voltage compensation, a new control mechanism and a fuzzy hysteresis band voltage methodology were implemented for the Unified Power Quality Conditioner (UPQC) (Drozdov et al., 2018). Furthermore, the purpose of UPQC is to produce the required reactive power to meet the demand, with the aim of minimizing the overall expenses of operation (Khadkikar and Chandra, 2008). A PIC-based artificial neural network (ANN) hybrid controller was then created for the Unified Power Quality Conditioner's (UPQC) Series Hybrid Active Power Filter (SHAPF) to effectively regulate current (Kinhal, Agarwal, & Gupta, 2011).

In order to minimize power loss in the converter, the UPQC (Leon et al., 2011) incorporated the optimal linearization feedback control method, which involved determining the most suitable angle for the load voltage. Furthermore, a comprehensive examination was conducted on the advanced techniques and remuneration strategies employed in the Unified Power Quality Conditioner (UPQC) as outlined by Khadkikar in 2012. In order to reduce PQ difficulties, costs, and losses, it was suggested that UPQCs be strategically positioned utilizing the differential evolution technique (Taher and Afsari, 2012). Furthermore, Yang, Soh, and Yap (2019) provide a design for a 3-level inverter architecture that utilizes Unified Power Quality Conditioner (UPQC) with Fuzzy Logic Control (FLC) to mitigate voltage fluctuations and minimize harmonic distortions.

In order to reduce fluctuations in voltage and current in distribution systems, a PV integrated UPQC was created (Gopal Murthy, and Sreenivas, 2016). Gadgune and Waware (2014) proposed an Integral-plus-SMC based controller for the voltage regulator in UPQC to maintain a constant voltage across the DC connection (Vdc) with a faster settling time and no overshoot. Nevertheless, a recent study conducted by Kalair et al. in 2017 scrutinized the body of literature pertaining to harmonic removal approaches, total harmonic distortion (THD) analysis, and power factor correction procedures. Furthermore, the integration of UPQC with the microgrid effectively addressed PQ related issues for different types of loads, as demonstrated by Samal and Hotaa in 2017. A comparison was conducted between the Total Harmonic Distortion (THD) performances of Unified Power Quality Conditioner (UPQC) and Distribution Static Compensator (DSTATCOM) at a steel plant that operates an induction furnace load (Saggu et al., 2018). The development of an SMC-based hybrid controller for UPQC was required in order to reduce current THD and grid-voltage distortion (Yavari, Edjtahed, and Taher, 2018).

The Levenberg Marquardt (LM) back propagation trained artificial neural network (ANN) method was created for the five level unified power quality conditioner (UPQC) in order to eliminate the requirement for intricate calculations and the construction of reference signals for DC Link balancing and current generation (Vinnakoti and Kotaa, 2018). Dash and Ray (2018) proposed a PV-tied UPQC topology with LCL filters and integrated sliding mode control to address voltage and current problems related to PQ. In order to further decrease the Total Harmonic Distortion (THD) and improve the power factor, the 5-level Unified Power Quality Conditioner (UPQC) was implemented. This implementation, as described by Nagireddy, Kota, and Ashok Kumar in 2018, utilizes the fuzzy-back-propagation controller technique. The predator-prey based firefly optimization (PPFO) technique was developed by Mahaboob, Ajithan, and Jayaramann to reduce total harmonic distortion (THD) and enhance the voltage profile in the design of a SHAPF (Selective Harmonic Active Power Filter).

Page | 304



ISSN 2249-3352 (P) 2278-0505 (E)

Cosmos Impact Factor-5.86

In their study, Nandhini and Sivaprakasamm (2020) analyzed the benefits and drawbacks of different PWM control systems that utilize Space Vector Pulse Width Modulation (SVPWM). The DC connection supported by PV and BSS connected UPQC was designed to mitigate current harmonics caused by fluctuations in the grid voltage (Mansor et al., 2020).

II. System deign

UPQC research has recently focused on micro-grids and distributed power generation. Unified power quality conditioners are of greater significance for a solar photovoltaic system compared to a conventional grid-connected voltage source converter. Important objectives include safeguarding sensitive loads from disturbances originating from the power grid and ensuring that the converter has a high level of competency in handling abrupt changes in electrical conditions. When employing a combined PV system with a UPQC, it is not possible to determine the neural phase for signal-phase loads, as they are considered mutual loads in a distribution system. Generating a reference signal is essential in the context of UPQC. The signal-generation techniques outlined in the literature.



Figure 1. Proposed UPVBSS configuration.



ISSN 2249-3352 (P) 2278-0505 (E)

Cosmos Impact Factor-5.86



Figure 2. RES connected DC link for UPQC

The series compensator and shunt compensator of UPQC and PV utilize advanced approaches in the time and frequency domains as a basis for their operation. Time domain-based methodologies are commonly embraced in real-time applications because of their minimal processing demands. Methods such as instantaneous symmetrical component theory, instantaneous reactive power theory, and synchronous reference frame theory are commonly used.

The presence of a second harmonic component in the d-axis current is a disadvantage of the synchronous-based reference frame theory in the case of unbalanced loads. The low pass filter (LPF) is employed to eliminate the double harmonic component by utilizing a low cutoff frequency.



Figure 3. PV solar system controller.

a) Proposed UPVBSS Configuration

Figure 1 illustrates the proposed UPVBSS configuration. The BSS is linked to the UPQC's DC connection via a buck-boost converter, while the solar PV is connected to the

Page | 306



ISSN 2249-3352 (P) 2278-0505 (E)

Cosmos Impact Factor-5.86





Figure 4 PV power system configuration

If Vsa, Vsb, and Vsc represent the voltages of the source bus for the a, b, and c phases of the grid, then Vl, il represent the current and voltage at the load. Source resistance is denoted by Rs, and source inductance by Ls. The UPQC combines series and shunt VSCs into a single unit. By injecting the correct compensating voltage Vse through the transformer, series APF can solve grid-voltage-related issues. Resistor Rse, inductor Lse, and capacitor Cse make up the RLC filter; resistance Rsh, inductance Lsh, and capacitance Csh connect the SHAPF to the grid. By injecting a compensating current, SHAPF can stabilise the Vdc with minimal settling time and lower the harmonic content of the current waveform.

b) PV Power Plant

The SPG system harnesses sun photons and transforms them into practical energy. The main elements of the system consist of B-C and PV arrays that are arranged in either a series or parallel arrangement, utilizing MPPT technology. The performance of the Solar Power Generator (SPG) is dependent on the intensity of solar radiation received by the strategically positioned Photovoltaic (PV) cells. Incorporating a solar system into the DC link can decrease the ratings, burden on power converters, and utility consumption. Figure 4 illustrates the configuration of a photovoltaic (PV) power system. The efficiency of a solar photovoltaic (PV) system is determined.

 $P_{PV} = V_{PV} \times i_{PV}$

Page | 307



ISSN 2249-3352 (P) 2278-0505 (E)

Cosmos Impact Factor-5.86



Figure 5 Proposed ANN control system.

VPP and IPP denote the voltage and current generated by a photovoltaic (PV) array. In order to optimize the output power and regulate the duty-cycle (D) of the boost converter, the High-Frequency Switching Modulation Controller (HFSMC) is suggested as the Maximum Power Point Tracking (MPPT) method.



Figure 6. BSS controller with Buck-Boost.

b) Proposed hybridised control

The main objective of this technology is to optimize the output of a photovoltaic panel by implementing Maximum Power Point Tracking. The control system proposed is depicted in Figure 5, where Fuzzy and sliding-mode control are combined.

$$U = U_{Fuzzy} + U_{flsmc}$$

 $U = U_{fuzzy} + K.Satu(s(x))$

Page | 308



ISSN 2249-3352 (P) 2278-0505 (E)

Cosmos Impact Factor-5.86





Figure 8 Switched-Shunt Voltage-Stabilized-Current Controller.

III. Simulation Result Analysis



Page | 309



ISSN 2249-3352 (P) 2278-0505 (E)

Cosmos Impact Factor-5.86



(b) Vs, Vse and Vl Figure 9 Casel (a) and (b)

Figure 9(a) illustrates the planned UPVBSS, including the loads and grid. Figure 9(b) shows a solar PV model with fluctuating irradiance. Figure 9(c) offers the suggested ANNC technique for the SHAPF and SAPF. The system and UPQC parameters are displayed in Table 4. In order to showcase the exceptional efficiency of the designed Artificial Neural Network Controller (ANNC) on the developed Uninterruptible Power and Voltage Balancing System (UPVBSS), five different scenarios were examined.



(c) Is, Iinj and Il

Page | 310



ISSN 2249-3352 (P) 2278-0505 (E)

Cosmos Impact Factor-5.86



(d) PV_irr, PV_temp and Vdc Figure 9 Case1 (c) and (d)

In scenario 1, the voltage source (VS) is considered to be in equilibrium. To evaluate the performance of the SAPF, a 30% decrease and increase in voltage, known as sag and swell, respectively, are introduced. These conditions are illustrated in Figure 9(a). In order to mitigate the effects of voltage drop, voltage increase, and disturbance, ANNC employs a coupling transformer to introduce a compensatory voltage, thus maintaining a stable voltage level at the load terminals. Figure 9(b) illustrates the voltage waveforms during steady-state conditions.



(a) Vs, Vse and Vl

Page | 311



ISSN 2249-3352 (P) 2278-0505 (E)

Cosmos Impact Factor-5.86



(b) Vs, Vse and Vl

Figure 10 Case2 (a) and (b)

The system assumes a balanced voltage source and introduces a disturbance of 30% sag and swell to evaluate the performance of SAPF. Figure 10(a) demonstrates the effective compensation achieved by the suggested technique, whereas Figure 10(b) displays the steadystate voltage waveforms. In example 2, we keep all other factors constant except for the irradiance, which decreases from 1000 W/m2 to 800 W/m2, while maintaining the temperature at 250 C. Figure 10(c) illustrates the il waveform, which was found to be non-sinusoidal but nonetheless evenly distributed. The proposed method effectively reduces the Total Harmonic Distortion (THD) of the current from 8.88% to 3.55%, surpassing the performance of the Power Inverter Converter (PIC).

Page | 312



ISSN 2249-3352 (P) 2278-0505 (E)

Cosmos Impact Factor-5.86



(c) Is, Iinj and Il



(d) PV_irr, PV_temp and Vdc

Figure 10 Case2 (c) and (d)

In Case 3, we evaluate the effectiveness of SAPF by subjecting a balanced voltage source to a 30% decrease, a 30% increase, and a 30% disturbance in source voltage. ANNC has the capability to identify voltage drop, voltage increase, and disruption produced by an unbalanced two-phase power source. It effectively resolves these issues by injecting the required compensating voltage. Figure 11(b) depicts the voltage waveforms during a stable condition. Figure 10(c) demonstrates that when an unbalanced load was assessed to analyze the efficiency

Page | 313



ISSN 2249-3352 (P) 2278-0505 (E)

Cosmos Impact Factor-5.86

of SHAF, the il waveform was determined to be sinusoidal but imbalanced in one phase. The proposed methodology rectifies existing waveform anomalies.



(b) Vs, Vse and Vl

Figure 11 Case3 (a) and (b)

In the event of an unbalanced VS, as illustrated in Case 4 of Figure 12(a), the ANNC-controlled SAPF will identify the issue and rectify it by providing a voltage boost. Considering the balanced load, the il waveform depicted in Figure 12(b) was found to be non-sinusoidal but balanced. As can be observed in Figure 12(c) for 1000 W/m2 irradiation and 250c constant temperature, the suggested controller reduces the current THD from 5.33% to 3.24%.

Page | 314



ISSN 2249-3352 (P) 2278-0505 (E)

Cosmos Impact Factor-5.86



(c) Is, Iinj and Il





Figure 11 Case3 (c) and (d)

Page | 315





Page | 316



ISSN 2249-3352 (P) 2278-0505 (E)

Cosmos Impact Factor-5.86

(c) Is, Iinj and Il



Figure 12 Case4 (a), (b), (c), (d) and case 5 (e)

IV. Conclusion

In conclusion, the proposed power quality management approach for PVBSS systems, incorporating Fractional Order Control with Artificial Neural Networks, demonstrates significant advancements in power reliability and efficiency. By bypassing traditional transformations and leveraging UPQCs along with Levenberg-Marquardt-trained ANNCs, the system can directly generate reference signals for shunt and series converters, resulting in more efficient and streamlined control. The HFSMC-based MPPT system optimizes power extraction from photovoltaic sources, while the Battery Storage System ensures stable DC link voltage and rapid response to fluctuating load and irradiation conditions. Compared to conventional PIC-based systems, this approach reduces Total Harmonic Distortion (THD), improves power factor, and decreases DC link voltage settling time. Future research should explore heuristic optimization techniques to further refine parameter tuning, enhancing system efficiency and making this approach a promising solution for improved power quality in solar energy applications. Page | 317



ISSN 2249-3352 (P) 2278-0505 (E)

Cosmos Impact Factor-5.86

References

- 1. Alhejji, A., and M. I. Mosaad. 2021. Performance enhancement of grid-connected PV systems using adaptive reference PI controller. Ain Shams Engineering Journal 12 (1):541–54. doi:10.1016/j.asej.2020.08.006.
- 2. Banakhr, F. A., and M. I. Mosaad. 2021. High performance adaptive maximum power point tracking technique for off-grid photovoltaic systems. Scientific Reports 11 (1):1–13. doi:10.1038/s41598-021-99949-8.
- 3. Dash, S. K., and P. K. Ray. 2018. Design and modeling of single-phase PV-UPQC scheme for power quality improvement utilizing a novel notch filter-based control algorithm: An experimental approach. Arabian Journal for Science and Engineering 43 (6):3083–102. doi:10.1007/s13369-018-3116-3.
- 4. Dash, S. K., and P. K. Ray. 2018. Novel PV-tied UPQC topology based on a new model reference control scheme and integral plus sliding mode dc-link controller. International Transactions on Electrical Energy Systems 28 (7):e2564. doi:10.1002/etep.2564.
- 5. Derri, M., M. Bouzi, Lagrat, I, and Y. Fuzzy. 2016. Fuzzy sliding mode control for photovoltaic system. International Journal of Power Electronics and Drive Systems 7 (3):964.
- 6. Devassy, S., and B. Singh. 2021. Performance analysis of solar PV array and battery integrated unified power quality conditioner for microgrid systems. IEEE Transactions on Industrial Electronics 68 (5):4027–35. doi:10.1109/TIE.2020.2984439.
- 7. Dheeban, S. S., and N. B. Muthu Selvan. 2021. ANFIS-based power quality improvement by photovoltaic integrated UPQC at distribution system. IETE Journal of Research :1–19. doi:10.1080/03772063.2021.1888325.
- 8. Drozdov, D., S. Patil, C.-W. Yang, G. Zhabelova, and V. Vyatkin. 2018. Formal verification of protection functions for power distribution networks. In IECON 2018-44th Annual Conference of the IEEE Industrial Electronics Society, 3550–5. IEEE.
- 9. Fujita, H., and H. Akagi. 1998. The unified power quality conditioner: The integration of series-and shunt-active filters. IEEE Transactions on Power Electronics 13 (2):315–22. doi: 10.1109/63.662847.
- Gaddameedhi, S., K. Srilakshmi, K. K. Jyothi, G. Kalyani, Y. Aryan, K. Sumanth, and A.Palanivelu. 2021. Hybrid controller based solar-fuel cell integrated UPQC for power quality enhancement. International Journal of Renewable Energy Research (IJRER) 11 (4):1673–83.
- Gadgune, S. Y., and M. M. Waware. 2014. A novel control strategy for capacitor voltage regulation of unified power quality conditioner using integral plus sliding mode controller. In 2014 International Conference on Circuits, Power and Computing Technologies [ICCPCT-2014], 45–52. IEEE.
- Gandoman, F. H., A. Ahmadi, A. M. Sharaf, P. Siano, J. Pou, B. Hredzak, and V. G.Agelidis. 2018. Review of FACTS technologies and applications for power quality in smart grids with renewable energy systems. Renewable and Sustainable Energy Reviews 82:502–14. doi:10.1016/j.rser.2017.09.062.

Page | 318



ISSN 2249-3352 (P) 2278-0505 (E)

Cosmos Impact Factor-5.86

- 13. Ghosh, S. C., and S. B. Karanki. 2017. PV supported unified power quality conditioner using space vector pulse width modulation. In 2017 National Power Electronics Conference (NPEC), 264–9. IEEE.
- 14. Gopal, B., P. K. Murthy, and G. N. Sreenivas. 2016. Power quality improvement using UPQC integrated with distributed generation network. International Journal of Electrical and Computer Engineering 8 (7):1216–24.
- 15. Jin, T., Y. Chen, J. Guo, M. Wang, and M. A. Mohamed. 2020. An effective compensation control strategy for power quality enhancement of unified power quality conditioner. Energy Reports 6:2167–79. doi:10.1016/j.egyr.2020.07.027.
- Kalair, A., N. Abas, A. R. Kalair, Z. Saleem, and N. Khan. 2017. Review of harmonic analysis, modeling and mitigation techniques. Renewable and Sustainable Energy Reviews 78: 1152–87. doi:10.1016/j.rser.2017.04.121.
- Khadkikar, V., and A. Chandra. 2008. A new control philosophy for a unified power quality conditioner (UPQC) to coordinate load-reactive power demand between shunt and series inverters. IEEE Transactions on Power Delivery 23 (4):2522–34. doi:10.1109/TPWRD.2008.921146.
- Khadkikar, V. 2012. Enhancing electric power quality using UPQC: A comprehensive overview. IEEE Transactions on Power Electronics 27 (5):2284–97. doi:10.1109/TPEL.2011.2172001.
- 19. Kinhal, V. G., P. Agarwal, and H. Gupta. 2011. Performance investigation of neuralnetworkbased unified power-quality conditioner. IEEE Transactions on Power Delivery 26 (1):431– 7. doi:10.1109/TPWRD.2010.2050706.
- 20. Kolhatkar, Y. Y., R. R. Errabelli, and S. P. Das. 2005. A sliding mode controller based optimum UPQC with minimum VA loading. In IEEE Power Engineering Society General Meeting, 2005, 871–5. IEEE.
- Leon, A. E., S. J. Amodeo, J. A. Solsona, and M. I. Valla. 2011. Non-linear optimal controller for unified power quality conditioners. IET Power Electronics 4 (4):435–46. doi:10.1049/iet-pel.2010.0134.
- 22. Mahaboob, S., S. K. Ajithan, and S. Jayaraman. 2019. Optimal design of shunt active power filter for power quality enhancement using predator-prey based firefly optimization. Swarm and Evolutionary Computation 44:522–33. doi:10.1016/j.swevo.2018.06.008.
- 23. Mansor, M. A., K. Hasan, M. M. Othman, S. Z. B. Mohammad Noor, and I. Musirin. 2020. Construction and performance investigation of three-phase solar PV and battery energy storage system integrated UPQC. IEEE Access.8:103511–38. doi:10.1109/ACCESS.2020.2997056.
- 24. Mosaad, M. I., N. A. Sabiha, A. Abu-Siada, and I. B. Taha. 2022. Application of superconductors to suppress ferroresonance overvoltage in DFIG-WECS. IEEE Transactions on Energy Conversion 37 (2):766–77. doi:10.1109/TEC.2021.3126602.

Page | 319